



# City of Columbia, Missouri

## Meeting Minutes

### Building Construction Codes Commission

---

Monday, December 16, 2024  
4:00 PM

International Electric Code Review by subcommittee

Columbia Convention  
& Visitors Bureau, 300  
S. Providence Rd,  
Columbia MO 65203

---

#### I. CALL TO ORDER

City Staff Attendance: Curtis Lichty and Aaron Decker

Meeting was called to order at 4:00pm by Richard Shanker (Noordsy was running late).

**Present:** 5 - Richard Shanker, Christopher Howe, Jim Dove, Andy Noordsy and Dan Shifley

**Excused:** 3 - Fred Malicoat, John Neyens and Kyle Saunders

#### II. APPROVAL OF AGENDA

**Motion to approve agenda.**

#### III. APPROVAL OF MINUTES

**Attachments:** [NEC Meeting Minutes 12-09-2024](#)

**Motion to approve Minutes.**

#### IV. OLD BUSINESS

Continue the review from previous meeting of 12-9-2024

Rick Shanker began discussion with 406.12 Tamper Resistant Receptacles.

Noordsey arrived during discussion of this item. Current amendments exempt 1 and 2 family dwelling units through that amendment. Jim Dove asked why 1 and 2 family are more special than the remaining locations to require them and especially compared to apartment buildings. Jim Dove made motion "to accept the NEC as written without the 1 and 2 family dwelling amendment that exempts them" Dan Shifley 2nd the motion. Discussion occurred and background on the amendment was made. Shanker calls to vote, call to vote was passed. Vote on Jim Dove's motion: 2 ayes, 3 naves. Motion denied.

Shanker motions to include the 1 and 2 family amendment to exempt them and then keep the remaining NEC language as written. Howe 2nd. Vote 5 ayes. Passed.

422.5 GFCI protection of appliances was reviewed. All agreed to maintain position of 2021 review and send the sump pump portion of this code to the BCCC for

review.

422.16 (2) (5) was reviewed and committee agreed to recommend removing the first sentence and keep the second sentence to maintain current allowance of receptacle behind the dishwasher in the same space.

445.18 was reviewed and approved.

450.9 was reviewed and approved.

518.6 Assembly Occupancies. Was reviewed and approved.

625.54 was reviewed and discussed. It was recommended to review with the 2023 changes in coming weeks.

680.22(A)(5) was reviewed and approved.

690.13(A) was reviewed and approved.

705.11 (B) was reviewed and approved.

## V. NEW BUSINESS

## VI. GENERAL COMMENTS BY PUBLIC, MEMBERS AND STAFF

## VII. NEXT MEETING DATE JANUARY 6, 2025

## VIII. ADJOURNMENT

Adjourn at 5:00pm.

### **Motion to adjourn meeting.**

Members of the public may attend any open meeting. For requests for accommodations related to disability, please call 573-874-CITY (573-874-2489) or email CITY@CoMo.gov. In order to assist staff in making the appropriate arrangements for your accommodation, please make your request as far in advance of the posted meeting date as possible.

**USB DRIVES PROHIBITED: Due to cybersecurity concerns, flash drives and other media devices are no longer permitted for delivering files or presentation materials. A speaker who desires to display a presentation must upload the presentation, in advance, to the city network using an upload portal. To upload your files and learn more, visit CoMo.gov/upload. (Effective Jan. 1, 2023)**