

Introduced by Treece Council Bill No. R 109-16

A RESOLUTION

setting a public hearing; declaring the necessity for the proposed replacement and upgrade of water mains along portions of Elaine Drive, Alan Circle, Kent Drive, Gregory Drive and Teresa Drive in the Gregory Heights Subdivision; stating the nature of and the estimate of the cost of the proposed improvement; providing for payment for the proposed improvement.

BE IT RESOLVED BY THE COUNCIL OF THE CITY OF COLUMBIA, MISSOURI, AS FOLLOWS:

SECTION 1. A public hearing in respect to the proposed public improvements set forth herein will be held in the Council Chamber of the City Hall Building, 701 E. Broadway, Columbia, Missouri, at 7:00 p.m. on September 6, 2016. The City Clerk shall cause notice of this hearing to be published in a newspaper published in the City.

SECTION 2. The City Council deems the proposed replacement and upgrade of 2-inch and 4-inch water mains with 6-inch PVC water mains along portions of Elaine Drive, Alan Circle, Kent Drive, Gregory Drive and Teresa Drive in the Gregory Heights Subdivision, necessary to the welfare and improvement of the City. Specific improvements include the following:

- Installation of 250 feet of water main and a fire hydrant on Elaine Drive.
- Replacement of 780 feet of water main and relocation of a fire hydrant on Alan Circle.
- Replacement of 530 feet of water main on Kent Drive.
- Replacement of 740 feet of water main and a fire hydrant on Gregory Drive.
- Replacement of 440 feet of water main on Teresa Drive.

SECTION 3. The estimated cost of this proposed improvement is \$325,000.00.

SECTION 4. Payment for this proposed improvement shall be made from the Water and Electric Fund using funds appropriated in Capital Improvement Project No. WT0255.

ADOPTED this 15th day of August, 2016.

ATTEST:



City Clerk



Mayor and Presiding Officer

APPROVED AS TO FORM:



City Counselor