



CITY OF COLUMBIA

Columbia, Missouri

APPEAL APPLICATION TO THE BUILDING CONSTRUCTION CODES COMMISSION

Case 007

Notice of appeal from the Decision of Code Official in regard to the following described property in the City of Columbia, County of Boone, State of Missouri:

Legally described as (per www.showmeboone.com/assessor): LOT 802A THE VILLAS AT OLD HAWTHORNE
and known as (number and street) 5938 SCREAMING EAGLE

Applicant(s) request a variance or ruling with respect to the above described property.

On the 16TH day of APRIL, said code official disapproved FINAL INSPECTION

The reason he gave for such action was that NO OUTLET IN ISLAND FOR LOWER
LEVEL BAR

which does not comply with Section 210.50 of the I.B.C.,
as adopted by the City of Columbia, Missouri, which provides or requires that:
1 OUTLET IN KITCHEN ISLAND

A copy of the notice of said official is hereto attached.

The basis for this appeal, as permitted by the International Building Code as adopted by the City of Columbia, is:
(check **all boxes that apply**)

- ☐ The true intent of the Code or the rules legally adopted thereunder have been incorrectly interpreted.
- ☐ The provisions of the Code do not fully apply.
- ☐ An equally good or better form of construction can be used.
- ☒ Undue hardship* is created by strict compliance with the letter of the Code but has no significant effect on the health, safety and welfare of the public or any individual (*attach a cost estimate for hardship encountered)

Applicant is requesting a variance or ruling, or both, in the way of carrying out the strict letter of the Code because:

BAR ISLAND WAS ADDED BY CUSTOMER AFTER FLOORING WAS INSTALLED

Applicant is proposing: NO PLUG IN BAR ISLAND

Name (Print) DON STCHLDRIETZ Agent (Print) SAME

Name of Business requesting variance LIFESTYLE HOMES

Address 5818 SCREAMING EAGLE Phone 573-268-9000

[Signature] 4-17-18

Applicant Signature

Date

Deliver Application with required \$120.00 check to:

Building Construction Codes Commission
Building and Site Development
701 East Broadway, 3rd Floor
Columbia, Missouri 65201



CITY OF COLUMBIA, MISSOURI

COMMUNITY DEVELOPMENT

DEPARTMENT OF PLANNING AND DEVELOPMENT

(573) 874-7239

BUILDING AND SITE DEVELOPMENT

(573) 874-7474

OFFICE OF NEIGHBORHOOD SERVICES

(573) 817-5050

Lifestyle Homes
5818 Screaming Eagle Lane
Columbia, Mo 65201

April 16, 2018

RE: 5938 Screaming Eagle Lane 16-2480

The request to not install receptacle outlets at island countertop spaces in the building above is denied for the following reasons;

1. The 2015 International Residential Code (Section E3901.4.2) and the 2014 National Electric Code (Section 210.50 (B) (2)) state, "At least one receptacle outlet shall be installed at each island countertop space with a long dimension of 24 inches or greater and a short dimension of 12 inches or greater."

You may apply for an appeal to the BCCC pursuant to the Columbia Code of Ordinances Section 6-17, 113.2.

Sincerely,

John P. Simon
Building Regulation Supervisor
john.simon@como.gov
573-874-7259